



# Read Me First

## Powerware 9125 700–2000 VA UPS Internal Battery Connection Instructions

Use the following procedure to ensure proper battery operation before installing the UPS:

- 1** Verify that the UPS is off and unplugged.
- 2** Remove the UPS front panel.
- 3** Connect the internal battery connector.
- 4** Reinstall the UPS front panel.
- 5** Refer to the *Powerware 9125 UPS (700–2000 VA) User's Guide* for UPS installation instructions.

If the UPS requires any type of transportation in the future, disconnect the UPS internal battery connector using the above steps in reverse order. If you need additional assistance, refer to the user's guide for contact information.

